

COMPARISON CHART

| Spec/Bidder | 1 Stop Wellness - Vollara | Air Cleaning Systems -Ulitmatum | Air Sniper | Alen Corp Breathsart 75i | Alliance building | Capital Business / Aura Air | Greenworks | Purewellness | Technology Int. |
|---|---------------------------|---------------------------------|---------------|--------------------------|-------------------------|-----------------------------|--------------|----------------------|-------------------------|
| Wall mountable | Not Mentioned | Yes | Not Mentioned | Not Mentioned | Item is the NV900/NV200 | Yes | No | Yes | Item is the NV900/NV213 |
| Operating Temp | 34-10F | Not Mentioned | c | Not Mentioned | Item is the NV900/NV201 | 32-104 F | | Not Mentioned | Item is the NV900/NV214 |
| Operating Humidity | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Item is the NV900/NV202 | Not Mentioned | | Not Mentioned | Item is the NV900/NV215 |
| Electric input | 100-240vac | 115 volt | 110V ac | Not Mentioned | Item is the NV900/NV203 | 110-240 V | | 120 V or 230 V | Item is the NV900/NV216 |
| Power consumption low | | Not Mentioned | Not Mentioned | 7 watts | Item is the NV900/NV204 | Not Mentioned | | 11 watts | Item is the NV900/NV217 |
| Power consumption high | | 69watts | 6amps | 45 watts | Item is the NV900/NV205 | Not Mentioned | | 46 watts | Item is the NV900/NV218 |
| Speeds | variable | 4 | 10 | 5 | Item is the NV900/NV206 | Multiple | 10 | 4 | Item is the NV900/NV219 |
| CFM low | 40 | 400,740 | 300 | Not Mentioned | Item is the NV900/NV207 | 206cfm | | 22cfm/49 cfm | Item is the NV900/NV220 |
| CFM high | 60 | 800,1000 | 800 | Not Mentioned | Item is the NV900/NV208 | Not Mentioned | 77 gal/sec | 79cfm/150 cfm | Item is the NV900/NV221 |
| Decibel low | 45 | 41-45 | Not Mentioned | 25 | Item is the NV900/NV209 | Not Mentioned | | 37/42 | Item is the NV900/NV222 |
| Decibel hight | 55 | 49-59 | Not Mentioned | 49 | Item is the NV900/NV210 | Not Mentioned | | 49/59 | Item is the NV900/NV223 |
| ISO 9001 | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Item is the NV900/NV211 | Not Mentioned | | Not Mentioned | Item is the NV900/NV224 |
| ISO 14001 | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Item is the NV900/NV212 | Not Mentioned | | Not Mentioned | Item is the NV900/NV225 |
| OHSAS 45001 | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Item is the NV900/NV213 | Not Mentioned | | Not Mentioned | Item is the NV900/NV226 |
| Air filtration | Yes | Yes | Not Mentioned | Yes | No | Yes | Yes | Yes | No |
| Hepa 99.97 .3microns + dust,mold, pollen bacteria | Yes | Yes | Not Mentioned | Yes | No | Yes | Yes | Yes | No |
| Particle efficiency | .3 microns + | .3 microns + | | .3 microns + | <.0001 micron | .3 microns + | .3 microns + | .007 microns | <.0001 micron |
| Carbon filter | Yes | Not Mentioned | Not Mentioned | Not Mentioned | No | Yes | Yes | Yes | No |
| Designed to remove allergens, dust, pollen | Yes | Yes | Not Mentioned | Not Mentioned | Yes | Yes | Yes | Yes | Yes |
| Ionizer | No | Yes | Appears so | No | Item is the NV900/NV213 | Yes | | No | Item is the NV900/NV226 |
| Service area | 500sq ft | Not clear | Not Mentioned | 1300 sq ft | Item is the NV900/NV213 | 350 m /hr | | 550 sq ft/1200 sq ft | Item is the NV900/NV226 |
| UV light disinfection | No | No | No | No | No | Yes | | No | No |
| Air quality monitor | No | No | No | No | No | No | No | Yes Temtop | No |
| Nanostrike (patented tech) | No | No | No | No | Yes | No | No | Equavalent | Yes |
| Use 24/7 | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Yes | Not Mentioned | | Equavalent | Yes |
| Safe near vulnerable people | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Yes | Not Mentioned | | Equavalent | Yes |
| Low energy usage | Not Mentioned | No | Yes | Yes | Yes | Not Mentioned | | Equavalent | Yes |
| Remove virus and bacteria | Not Mentioned | Not Mentioned | Not Mentioned | Not Mentioned | Yes | Yes | | Equavalent | Yes |
| Meet Purifier Specifications | No | No | No | No | Yes | No | No | No | Yes |